

CLARIFICATIONS ON QUERIES / ADDENDUMS ON TENDER NOTICE dated: 04/07/2016 FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 60 TONNE CAPACITY WEIGH BRIDGE AT RED SANDERS GODOWN COMPLEX, TIRUPATI, CHITTOOR DISTRICT, ANDHRA PRADESH

Ref: Tender Notice Number: 09/CE-I/APIIC/2015-16 Dt: 04/7/2016

S.No	Query / Submission	APIIC Reply to Queries/ Addendums
1	Having gone through the tender, we have observed the platform size required is 16 M x 4 M. Kindly clarify is this the requirement or it should read as 16 M x 3 M. Please clarify.	After care full consideration of the requirements it was decided that the platform size required is modified to 16m x 3m. (Clause 1.4 Scope of supply)
2	As per the Technical Data Sheet Precision Load Cell - Kindly clarify the type of Load Cell [not mentioned clearly] to be supplied & material of Construction - whether the manufacturer can supply Tool Steel also. Please clarify.	Tender document condition will prevail. Pl refer Clause 2.3 read along with 2.3.2.
3	Quantity of Load Cells: It is mentioned as 6 nos and above in Technical Data Sheet, whereas in Technical Specification 2.3.4 [G: Load Cell] you have mentioned up to 10 Nos. Please clarify.	No discrepancy. Tender Document condition of 2.3 will prevail.
4	Technical specifications - Weigh Bridge indicator - You have mentioned spec pertaining to a particular Manufacturer - Avery make... With this the other vendors though having superior features who would like to serve you better with their design, performance, accuracy etc will get defeated...Hence request you to revise the Specifications as per the manufacture's design and to meet the recent technology, thus giving opportunity for other vendors to show case their products . Please clarify.	The tender document is not making any specific reference to particular manufacturer. The technical specification of Tender document will prevail.

(Signature)
MCE
DGM(E)


(Signature)
Chief Engineer - I
APIIC, Hyderabad.

CLARIFICATIONS ON QUERIES / ADDENDUMS ON TENDER NOTICE dated: 04/07/2016 FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 60 TONNE CAPACITY WEIGH BRIDGE AT RED SANDERS GODOWN COMPLEX, TIRUPATI, CHITTOOR DISTRICT, ANDHRA PRADESH

S.No	Query / Submission	APIIC Reply to Queries/Addendums
5	We also request you to kindly extend the submission date of the Tender from 18th July 2016 by another 10 days so that it will enable us to participate.	Time frames given in the Tender document will prevail
6	<p>2.3.4 Technical specification weigh bridge</p> <p>J. Computer: 1 no. PC, P-IV, 1 GBRAM, 160 GB HDD, DVD combo/writer, 22"Color LCD monitor with Windows XP operating system, key board(recent edition) & cordless mouse. Make -HP, Compaq or as approved by EIC.</p> <p>K. Printer: 2 nos. Model LX 300 +, Type - Dot Matrix with 80 columns, one for indicator& other for PC. Make - HP</p>	<p>2.3.4 Technical specification weigh bridge shall be read as</p> <p>J. Computer: 1 no. PC, I-6, 4 GBRAM, 500 GB HDD, DVD combo/writer, 24" or above, Full HD LED monitor with Windows 10 operating system, key board(recent edition) & cordless mouse. Make -HP, Compaq, Dell. Lenovo or as approved by EIC.</p> <p>K. Printer: 2 nos. One Type - Dot Matrix with 80 columns, and Second B/W A4 Size Laser printer , one for indicator& other for PC. Make - HP/TVS/Epson/Canon or as approved by EIC.</p>

M(E) 11/7/16

 DGM(E)


Chief Engineer-I
APIIC, Hyderabad.