


ESTABLISHMENT OF 1 MLD COMMON EFFLUENT TREATMENT PLANT (CETP)
ON EPC MODE INCLUDING O&M FOR A PERIOD OF 10 YEARS AT MPSEZ,
NAIDUPETA, SPSR NELLORE DISTRICT
NATIONAL COMPETITIVE BIDDING (NCB)
ADB Loan No: L3430-IND

Response to Prebid Queries – Additional - Addendum - 2

SI No	Ret Document / Page no./ Clause ref.	Bidder's query	Responses By APIIC
1.	General: Scope of work	We have not found anything specific about Scope of Work & Exclusion for Instrumentation & Control Items. Please provide the same.	Bidder to ensure all necessary instrumentation and control items required for effective functioning of the CETP as a part of the scope of work.
2.	Volume IA, Section-4, Schedule No.5: Recommended Spare Part	As per Recommended Spare Part List, PLC and Instrument Part is mentioned. It is recommended Spare. Please confirm, if any Mandatory or commissioning spares are required.	Bidder has to ensure that sufficient spare parts are available so that there is no breakdown in the plant due to non-availability of spares.
3.	General, Technical Specifications	Please provide detailed technical specification for Instrumentation & Control items etc. or shall we consider it as per good engineering practice.	As part of section 1.3.9 of Volume 2 technical specification indicative specifications are mentioned. Bidder to consider as per good engineering practice.
4.	General, Vendor List	Please provide Vendor list for Instrumentation & Control Items etc.	List of approved makes are mentioned in Volume 2 technical specification, apart from those bidder to consider standard makes conforming to IS or relevant standards
5.	General, Battery limits	Please confirm the battery limit and availability of voltage level of the incoming power supply at the transformer end.	33 / 11 KV Sub Station is located with in MP SEZ. Bidder has to facilitate Power supply. Any Statutory payment towards obtaining power supply will be made by APIIC.
6.	General, Technical Specification	Please provide the Technical Specifications for Electrical Equipment's	Bidder to consider standard technical specifications as per supplier/ manufacturer complete for the proper, safe and effective operations of the CETP.


 Chief Engineer-1
 APIIC Ltd., Vijayawada

7.	General, Scope of work	<p>1. Please provide the detailed Electrical Scope of Work for the 1 MLD CETP.</p> <p>2. Also please confirm if the incomer power cable to transformer shall be in contractor's scope of supply.</p> <p>3. We understand that the UPS, Earthing & Lightening Protection for the CETP shall be in APIICL's scope. Please confirm.</p>	<p>1. Cabling, automation and all associated ELECTRICAL WORKS for the successful commissioning and operation of the CETP shall be deemed to be part of this Tender.</p> <p>Work should be executed as per standards and specifications of APSPDCL under supervision of APSPDCL and APIIC officials.</p> <p>The electrical equipment and accessories shall be designed as per the Applicable Standards, Bureau of Indian Standards and IEEE Standards</p> <p>2. Refer S.no 5</p> <p>3. UPS, earthing & lightning protection for the CETP shall be in contractors scope</p>
8.	General	<p>1. Please confirm the location for Electrical MCC & PLC Room & Power Transformer.</p> <p>2. Also please confirm the location of substation from where the power supply is to be fed to the CETP transformer.</p>	<p>1. Bidder to finalise the locations in consultation with APIIC during execution.</p> <p>2. 33/11 KV Sub-station is located within the MPSEZ</p>
9.	Volume 1A, Section 4, Schedule No. 5, Recommended Spare Part	<p>Please confirm if any mandatory or commissioning spares are also required.</p>	<p>Refer S. no 2</p>
10.	Section-8 SCC, (Dispute & Arbitration), Clause 45 Sub Clause 45.2,	<p>Contracts with contractors being nationals of the Employer's country: Arbitration as per the Indian Laws</p> <p>We would propose that in case dispute is referred for arbitration, a panel of three Arbitrators (One Arbitrators by each party and the Arbitrator so appointed shall appoint a third presiding Arbitrator) should adjudicate the dispute as per the provision of Arbitration and Reconciliation Act, 1996 as amended from time to time. The language of Arbitration proceedings shall be English.</p> <p>Please confirm</p>	<p>As per RFP Section 7, Clause 45.2</p>


 Chief Engineer-1
 APIIC Ltd., Vijayawada Page 2 of 2
 6